



## POLLUTANT CONCENTRATION LIMITS

EPA Sample Point 1 - Deep Sea Release Effluent Quality Monitoring

Coffs Harbour Water Reclamation Works

EPA Licence 573

Coffs Harbour City Council

Locked Bag 155

Coffs Harbour NSW 2450

Reporting Period: 1 July 2016 - 30 June 2017

Current period: Year to published date

Sample Point 1 - Deep Sea Release

Test Frequency: Weekly

Date Published: Tuesday, 15 August 2017

[Click here to access this licence on the EPA website](#)

Pollutant	Unit of measure	Number of Tests reaching the 90 Percentile Concentration Limit	90 percentile concentration limit	Number of Tests reaching the 100 Percentile Concentration Limit	100 percentile concentration limit
Biochemical Oxygen Demand	mg/L	0	10	0	20
Nitrogen (total)	mg/L	0	10	0	20
Oil and Grease	mg/L	0	2	0	4
Phosphorus (total)	mg/L	0	2	0	4
Total suspended solids	mg/L	0	15	0	30

Notes: A limit condition may be specified as 90th percentile value over a year whereas the corresponding monitoring condition may require weekly monitoring. In this case, the monitoring results must not exceed the specified limit for only 90% of the specified period, not all the time. For weekly monitoring this means that at most five samples of the 52 samples taken over the year may be above the specified limit. The remaining 47 samples must have results below the limit.