

Reporting Period: 1 July 2016 - 30 June 2017

Current period: Year to published date

Date Published: Wednesday, 21 June 2017

[Click here to access this licence on the EPA website](#)

<b>Sample Point 8 - Moonee Water Reclamation Plant</b>					
<b>Pollutant</b>	<b>Unit of measure</b>	<b>Number of Tests reaching the 90 Percentile Concentration Limit</b>	<b>90 percentile concentration limit</b>	<b>Number of Tests reaching the 100 Percentile Concentration Limit</b>	<b>100 percentile concentration limit</b>
Faecal Coliforms	Cfu/100ml	0	200	0	600

<b>Sample Point 11 - Woolgoolga Water Reclamation Plant</b>					
<b>Pollutant</b>	<b>Unit of measure</b>	<b>Number of Tests reaching the 90 Percentile Concentration Limit</b>	<b>90 percentile concentration limit</b>	<b>Number of Tests reaching the 100 Percentile Concentration Limit</b>	<b>100 percentile concentration limit</b>
Faecal Coliforms	Cfu/100ml	0	200	0	600

<b>Sample Point 13 - Morgans Road Reservoir</b>					
<b>Pollutant</b>	<b>Unit of measure</b>	<b>Number of Tests reaching the 90 Percentile Concentration Limit</b>	<b>90 percentile concentration limit</b>	<b>Number of Tests reaching the 100 Percentile Concentration Limit</b>	<b>100 percentile concentration limit</b>
Faecal Coliforms	Cfu/100ml	0	200	0	600

<b>Sample Point 15 - Coffs Harbour Reuse</b>					
<b>Pollutant</b>	<b>Unit of measure</b>	<b>Number of Tests reaching the 90 Percentile Concentration Limit</b>	<b>90 percentile concentration limit</b>	<b>Number of Tests reaching the 100 Percentile Concentration Limit</b>	<b>100 percentile concentration limit</b>
Faecal Coliforms	Cfu/100ml	0	<b>200</b>	0	<b>600</b>

<b>Sample Point 19 - Corindi Reuse Onsite</b>					
<b>Pollutant</b>	<b>Unit of measure</b>	<b>Number of Tests reaching the 90 Percentile Concentration Limit</b>	<b>90 percentile concentration limit</b>	<b>Number of Tests reaching the 100 Percentile Concentration Limit</b>	<b>100 percentile concentration limit</b>
Faecal Coliforms	Cfu/100ml	1	<b>200</b>	1	<b>600</b>

<b>Sample Point 22 - Corindi Reuse Offsite</b>					
<b>Pollutant</b>	<b>Unit of measure</b>	<b>Number of Tests reaching the 90 Percentile Concentration Limit</b>	<b>90 percentile concentration limit</b>	<b>Number of Tests reaching the 100 Percentile Concentration Limit</b>	<b>100 percentile concentration limit</b>
Faecal Coliforms	Cfu/100ml	1	<b>200</b>	0	<b>600</b>

Notes: A limit condition may be specified as 90th percentile value over a year whereas the corresponding monitoring condition may require weekly monitoring. In this case, the monitoring results must not exceed the specified limit for only 90% of the specified period, not all the time. For weekly monitoring this means that at most five samples of the 52 samples taken over the year may be above the specified limit. The remaining 47 samples must have results below the limit.