

Reporting Period: 1 July 2017 to 30 June 2018

Current period: Year to published date

Date Published: Friday, 6 July 2018

[Click here to access this licence on the EPA website](#)

Sample Point 8 - Moonee Water Reclamation Plant					
Pollutant	Unit of measure	Number of Tests reaching the 90 Percentile Concentration Limit	90 percentile concentration limit	Number of Tests reaching the 100 Percentile Concentration Limit	100 percentile concentration limit
Faecal Coliforms	Cfu/100ml	0	200	0	600

Sample Point 11 - Woolgoolga Water Reclamation Plant					
Pollutant	Unit of measure	Number of Tests reaching the 90 Percentile Concentration Limit	90 percentile concentration limit	Number of Tests reaching the 100 Percentile Concentration Limit	100 percentile concentration limit
Faecal Coliforms	Cfu/100ml	0	200	0	600

Sample Point 13 - Morgans Road Reservoir					
Pollutant	Unit of measure	Number of Tests reaching the 90 Percentile Concentration Limit	90 percentile concentration limit	Number of Tests reaching the 100 Percentile Concentration Limit	100 percentile concentration limit
Faecal Coliforms	Cfu/100ml	0	200	0	600

Sample Point 15 - Coffs Harbour Reuse					
Pollutant	Unit of measure	Number of Tests reaching the 90 Percentile Concentration Limit	90 percentile concentration limit	Number of Tests reaching the 100 Percentile Concentration Limit	100 percentile concentration limit
Faecal Coliforms	Cfu/100ml	0	200	0	600

Sample Point 19 - Corindi Reuse Onsite					
Pollutant	Unit of measure	Number of Tests reaching the 90 Percentile Concentration Limit	90 percentile concentration limit	Number of Tests reaching the 100 Percentile Concentration Limit	100 percentile concentration limit
Faecal Coliforms	Cfu/100ml	2	200	2	600

Sample Point 22 - Corindi Reuse Offsite					
Pollutant	Unit of measure	Number of Tests reaching the 90 Percentile Concentration Limit	90 percentile concentration limit	Number of Tests reaching the 100 Percentile Concentration Limit	100 percentile concentration limit
Faecal Coliforms	Cfu/100ml	1	200	1	600

Notes: A limit condition may be specified as 90th percentile value over a year whereas the corresponding monitoring condition may require weekly monitoring. In this case, the monitoring results must not exceed the specified limit for only 90% of the specified period, not all the time. For weekly monitoring this means that at most five samples of the 52 samples taken over the year may be above the specified limit. The remaining 47 samples must have results below the limit.