

SAMPLE POINT DATA

EPA Sample Point 1 - Deep Sea Release Effluent Quality Monitoring

Coffs Harbour Water Reclamation Works

EPA Licence 573

Coffs Harbour City Council

Locked Bag 155

Coffs Harbour NSW 2450



Sample Point 3 - Effluent Quality Monitoring Deep Sea Release data for Sample Point 1

Reporting Period: 1 July 2019 to 30 June 2020

Test frequency: Weekly

[Click here to access this licence on the EPA website](#)

Notes: "<" This symbol means less than: it is typically equal to the limit of detection of the analytical procedure used.

Cells highlighted indicate results that reach Council's 90 and 100 percentile limits

Date Sample Collected	Date Obtained	Date Published	PH	Biochem Oxygen Demand BOD	Total Suspended Solids	Nitrate Nitrogen NO3N	Nitrite Nitrogen NO2N	Ammonia Nitrogen NH3N	Total Nitrogen	Total Phosphorus	Oil & Grease	Chlorine Free	Chlorine Total	Faecal Coliforms	Comments
			unit	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	mg/L	cfu/100ml	
2/07/2019	11/07/2019	17/07/2019	7.80	<2	3	1.07	0.03	0.30	1.81	0.15	<2	<0.01	<0.01	0	Batch 19/1529 - final
9/07/2019	17/07/2019	17/07/2019	7.80	<2	2	1.29	0.04	0.43	2.38	0.16	<2	<0.01	<0.01	5	Batch 19/1593 - final
16/07/2019	29/07/2019	29/07/2019	8.00	<2	2	2.39	0.12	0.26	3.19	0.13	<2	<0.01	<0.01	0	Batch 19/1661 - final
23/07/2019	5/08/2019	8/08/2019	7.90	<2	<2	1.47	0.10	0.15	2.40	0.16	<2	<0.01	<0.01	0	Batch 19/1721 - final
30/07/2019	5/08/2019	8/08/2019	8.00	<2	<2	1.33	0.05	0.08	2.01	0.18	<2	<0.01	<0.01	0	Batch 19/1776 - final
6/08/2019	19/08/2019	23/08/2019	7.50	<2	<2	4.69	0.08	0.10	5.29	0.05	<2	<0.01	<0.01	0	Batch 19/1834 - final
13/08/2019	20/08/2019	23/08/2019	7.90	4.00	5.00	4.37	0.10	0.06	5.32	0.22	<2	<0.01	<0.01	0	Batch 19/1898 - final
20/08/2019	27/08/2019	6/09/2019	8.00	3.00	5.00	3.58	0.07	0.16	4.35	0.25	<2	<0.01	<0.01	0	Batch 19/1945 - final
27/08/2019	3/09/2019	6/09/2019	8.00	2.00	4.00	2.44	0.07	0.17	3.50	0.36	<2	<0.01	<0.01	9	Batch 19/2007 - final
3/09/2019	18/09/2019	19/09/2019	8.10	2.00	3	1.70	0.06	0.14	2.63	0.24	<2	<0.01	<0.01	0	Batch 19/2079 - final
10/09/2019	18/09/2019	19/09/2019	8.10	2.00	8	2.39	0.08	0.05	3.40	0.27	<2	<0.01	<0.01	0	Batch 19/2131 - final
17/09/2019	24/09/2019	3/10/2019	8.10	<2	4	2.82	0.02	0.03	3.81	0.33	<2	<0.01	<0.01	0	Batch 19/2188 - final
24/09/2019	3/10/2019	3/10/2019	8.00	<2	2	1.69	0.03	0.09	2.38	0.20	<2	<0.01	<0.01	3	Batch 19/2263 - final