

SAMPLE POINT DATA
EPA Licence 573
Coffs Harbour City Council
Locked Bag 155
Coffs Harbour NSW 2450



Sample Point 8 - Effluent Quality Monitoring - Moonee WRP
 Reporting Period: 1 July 2018 to 30 June 2019
 Test Frequency: Monthly with additional weekly tests required by Council

[Click here to access this licence on the EPA website](#)

Notes:

Cells highlighted indicate results that reach Council's 90 and 100 percentile limits

Date Sample Collected	Date Obtained	Date Published	Faecal Coliforms cfu/100ml	Comments
3/07/2018	10/07/2018	16/07/2018	0	Batch 18/1414/1
10/07/2018	17/07/2018	18/07/2018	0	Batch 18/1473/1
16/07/2018	18/07/2018	18/07/2018	0	Batch 18/1521/1
24/07/2018	30/07/2018	6/08/2018	0	Batch 18/1569/1
31/07/2018	6/08/2018	6/08/2018	0	Batch 18/1615/1
7/08/2018	13/08/2018	24/08/2018	0	Batch 18/1662/1
14/08/2018	20/08/2018	24/08/2018	0	Batch 18/1721/1
21/08/2018	23/08/2018	4/09/2018	0	Batch 18/1772/1
28/08/2018	5/09/2018	6/09/2018	0	Batch 18/1823/1
4/09/2018	10/09/2018	24/09/2018	0	Batch 18/1893/1
11/09/2018	14/09/2018	24/09/2018	0	Batch 18/1959/1
18/09/2018	24/09/2018	4/10/2018	0	Batch 18/2013/1
25/09/2018	4/10/2018	4/10/2018	0	Batch 18/2073/1
3/10/2018	8/10/2018	18/10/2018	0	Batch 18/2152/1
9/10/2018	12/10/2018	18/10/2018	0	Batch 18/2190/1
16/10/2018	19/10/2018	31/10/2018	0	Batch 18/2260/1
23/10/2018	29/10/2018	31/10/2018	0	Batch 18/2305/1
30/10/2018	6/11/2018	9/11/2018	0	Batch 18/2365/1
6/11/2018	14/11/2018	22/01/2018	0	Batch 18/2438/1
13/11/2018	20/11/2018	22/01/2018	0	Batch 18/2497/1
20/11/2018	27/11/2018	11/12/2018	0	Batch 18/2572/1
27/11/2018	17/12/2018	17/12/2018	0	Batch 18/2628/1
4/12/2018	10/12/2018	17/12/2018	5	Batch 18/2688/1
11/12/2018	18/12/2018	18/12/2018	0	Batch 18/2760/1
18/12/2018	2/01/2019	14/01/2019	0	Batch 18/2839/1
20/12/2019	2/01/2019	14/01/2019	0	Batch 18/2867/1
3/01/2019	8/01/2019	14/01/2019	6	Batch 19/0033/1
8/01/2019	14/01/2019	14/01/2019	0	Batch 19/0057/1
15/01/2019	21/01/2019	25/01/2019	0	Batch 19/0132/1
22/01/2019	29/01/2019	7/02/2019	0	Batch 19/0190/1
29/01/2019	4/02/2019	7/02/2019	0	Batch 19/0243/1
5/02/2019	12/02/2019	26/02/2019	0	Batch 19/0302/1
12/02/2019	13/02/2019	26/02/2019	63	Batch 19/0368/1 RE SAMPLE REQUIRED
13/02/2019	14/02/2019	26/02/2019	0	Batch 19/0393/1
19/02/2019	25/02/2019	26/02/2019	0	Batch 19/0425/1
27/02/2019	11/03/2019	13/03/2019	0	Batch 19/0511/1
5/03/2019	12/03/2019	13/03/2019	0	Batch 19/0560/1
12/03/2019	19/03/2019	26/03/2019	0	Batch 19/0619/1
19/03/2019	25/03/2019	26/03/2019	0	Batch 19/0676/1
27/03/2019	1/04/2019	11/04/2019	0	Batch 19/0766/1
2/04/2019	8/04/2019	11/04/2019	0	Batch 19/0814/1
9/04/2019	16/04/2019	29/04/2019	0	Batch 19/0876/1
16/04/2019	23/04/2019	29/04/2019	0	Batch 19/0928/1
23/04/2019	30/04/2019	8/05/2019	0	Batch 19/0966/1
30/04/2019	7/05/2019	8/05/2019	0	Batch 19/1014/1
7/05/2019	14/05/2019	21/05/2019	0	Batch 19/1088/1
14/05/2019	20/05/2019	21/05/2019	0	Batch 19/1153/1
21/05/2019	23/05/2019	4/06/2019	0	Batch 19/1204/1
29/05/2019	11/06/2019	14/06/2019	0	Batch 19/1279/1
4/06/2019	11/06/2019	14/06/2019	0	Batch 19/1313/1
11/06/2019	13/06/2019	14/06/2019	0	Batch 19/1352/1
18/06/2019	20/06/2019	27/06/2019	0	Batch 19/1411/1
25/06/2019	2/07/2019	3/07/2019	0	Batch 19/1459/1

SAMPLE POINT DATA
EPA Licence 573
Coffs Harbour City Council
Locked Bag 155
Coffs Harbour NSW 2450



Sample Point 11 - Effluent Quality Monitoring - Woolgoolga WRP
 Reporting Period: 1 July 2018 to 30 June 2019
 Test Frequency: Monthly with additional weekly tests required by Council

[Click here to access this licence on the EPA website](#)

Notes:

Cells highlighted indicate results that reach Council's 90 and 100 percentile limits

Date Sample Collected	Date Obtained	Date Published	Faecal Coliforms cfu/100ml	Comments
3/07/2018	10/07/2018	16/07/2018	0	Batch 18/1416/1
10/07/2018	17/07/2018	18/07/2018	0	Batch 18/1493/1
16/07/2018	17/07/2018	18/07/2018	0	Batch 18/1514/1
24/07/2018	26/07/2018	6/08/2018	0	Batch 18/1572/1
31/07/2018	6/08/2018	6/08/2018	0	Batch 18/1616/1
7/08/2018	16/08/2018	24/08/2018	0	Batch 18/1663/1
14/08/2018	20/08/2018	24/08/2018	0	Batch 18/1728/1
21/08/2018	23/08/2018	6/09/2018	0	Batch 18/1781/1
28/08/2018	3/09/2018	6/09/2018	0	Batch 18/1834/1
4/09/2018	11/09/2018	24/09/2018	0	Batch 18/1885/1
11/09/2018	14/09/2018	24/09/2018	0	Batch 18/1961/1
18/09/2018	24/09/2018	4/10/2018	0	Batch 18/2024/1
25/09/2018	2/10/2018	4/10/2018	0	Batch 18/2070/1
2/10/2018	9/10/2018	18/10/2018	0	Batch 18/2129/1
9/10/2018	12/10/2018	18/10/2018	0	Batch 18/2191/1
16/10/2018	19/10/2018	31/10/2018	0	Batch 18/2261/1
23/10/2018	26/10/2018	31/10/2018	0	Batch 18/2308/1
30/10/2018	6/11/2018	9/11/2018	0	Batch 18/2355/1
6/11/2018	14/11/2018	22/11/2018	0	Batch 18/2432/1
13/11/2018	20/11/2018	22/11/2018	0	Batch 18/2519/1
20/11/2018	27/11/2018	11/12/2018	0	Batch 18/2577/1
27/11/2018	4/12/2018	17/12/2018	0	Batch 18/2634/1
4/12/2018	11/12/2018	17/12/2018	0	Batch 18/2701/1
11/12/2018	18/12/2018	18/12/2018	0	Batch 18/2754/1
18/12/2018	2/01/2019	14/01/2019	0	Batch 18/2832/1
20/12/2018	2/01/2019	14/01/2019	0	Batch 18/2869/1
3/01/2019	8/01/2019	14/01/2019	0	Batch 19/0036/1
8/01/2019	15/01/2019	25/01/2019	0	Batch 19/0058/1
15/01/2019	21/01/2019	25/01/2019	0	Batch 19/0137/1
23/01/2019	29/01/2019	7/02/2019	0	Batch 19/0214/1
29/01/2019	4/02/2019	7/02/2019	0	Batch 19/0244/1
5/02/2019	14/02/2019	26/02/2019	0	Batch 19/0318/1
12/02/2019	19/02/2019	26/02/2019	0	Batch 19/0369/1
19/02/2019	25/02/2019	26/02/2019	0	Batch 19/0429/1
26/02/2019	5/03/2019	13/03/2019	0	Batch 19/0486/1
5/03/2019	12/03/2019	13/03/2019	0	Batch 19/0561/1
12/03/2019	19/03/2019	26/03/2019	0	Batch 19/0622/1
19/03/2019	25/03/2019	26/03/2019	0	Batch 19/0680/1
26/03/2019	1/04/2019	11/04/2019	0	Batch 19/0746/1
2/04/2019	9/04/2019	11/04/2019	0	Batch 19/0821/1
9/04/2019	16/04/2019	29/04/2019	0	Batch 19/0879/1
16/04/2019	23/04/2019	29/04/2019	0	Batch 19/0939/1
23/04/2019	30/04/2019	8/05/2019	0	Batch 19/0963/1
30/04/2019	7/05/2019	8/05/2019	0	Batch 19/1032/1
7/05/2019	14/05/2019	21/05/2019	0	Batch 19/1089/1
14/05/2019	20/05/2019	21/05/2019	0	Batch 19/1155/1
21/05/2019	23/05/2019	4/06/2019	0	Batch 19/1208/1
28/05/2019	3/06/2019	4/06/2019	0	Batch 19/1257/1
4/06/2019	14/06/2019	14/06/2019	0	Batch 19/1314/1
11/06/2019	13/06/2019	14/06/2019	0	Batch 19/1357/1
18/06/2019	20/06/2019	27/06/2019	0	Batch 19/1418/1
25/06/2019	2/07/2019	3/07/2019	0	Batch 19/1470/1

Sample Point 13 - Effluent Quality Monitoring - Morgans Road Reservoir
 Reporting Period: 1 July 2018 to 30 June 2019
 Test Frequency: Monthly with additional weekly tests required by Council

[Click here to access this licence on the EPA website](#)

Notes:

Cells highlighted indicate results that reach Council's 90 and 100 percentile limits

Date Sample Collected	Date Obtained	Date Published	Faecal Coliforms cfu/100ml	Comments
	10/07/2018	16/07/2018	0	Batch 18/1417/1
10/07/2018	17/07/2018	18/07/2018	0	Batch 18/1494/1
16/07/2018	18/07/2018	18/07/2018	0	Batch 18/1515/1
24/07/2018	26/07/2018	6/08/2018	0	Batch 18/1573/1
31/07/2018	6/08/2018	6/08/2018	0	Batch 18/1617/1
7/08/2018	16/08/2018	24/08/2018	0	Batch 18/1664/1
14/08/2018	20/08/2018	24/08/2018	0	Batch 18/1729/1
21/08/2018	23/08/2018	6/09/2018	0	Batch 18/1782/1
28/08/2018	3/09/2018	6/09/2018	0	Batch 18/1835/1
4/09/2018	10/09/2018	24/09/2018	0	Batch 18/1886/1
11/09/2018	14/09/2018	24/09/2018	0	Batch 18/1962/1
18/09/2018	24/09/2018	4/10/2018	0	Batch 18/2025/1
25/09/2018	2/10/2018	4/10/2018	0	Batch 18/2071/1
2/10/2018	9/10/2018	18/10/2018	0	Batch 18/2128/1
9/10/2018	12/10/2018	18/10/2018	0	Batch 18/2192/1
16/10/2018	19/10/2018	31/10/2018	0	Batch 18/2262/1
23/10/2018	26/10/2018	31/10/2018	0	Batch 18/2309/1
30/10/2018	6/11/2018	9/11/2018	0	Batch 18/2356/1
6/11/2018	14/11/2018	22/11/2018	0	Batch 18/2433/1
13/11/2018	20/11/2018	22/11/2018	0	Batch 18/2520/1
20/11/2018	27/11/2018	11/12/2018	0	Batch 18/2578/1
27/11/2018	4/12/2018	17/12/2018	0	Batch 18/2635/1
4/12/2018	11/12/2018	17/12/2018	0	Batch 18/2702/1
10/12/2018	18/12/2018	18/12/2018	0	Batch 18/2733/1
18/12/2018	2/01/2019	14/01/2019	0	Batch 18/2831/1
20/12/2018	2/01/2019	14/01/2019	0	Batch 18/2868/1
3/01/2019	8/01/2019	14/01/2019	0	Batch 19/0035/1
10/01/2019	15/01/2019	25/01/2019	0	Batch 19/0059/1
15/01/2019	21/01/2019	25/01/2019	0	Batch 19/0138/1
23/01/2019	29/01/2019	7/02/2019	0	Batch 19/0215/1
29/01/2019	4/02/2019	7/02/2019	0	Batch 19/0245/1
5/02/2019	14/02/2019	26/02/2019	0	Batch 19/0319/1
12/02/2019	19/02/2019	26/02/2019	0	Batch 19/0370/1
19/02/2019	25/02/2019	26/02/2019	0	Batch 19/0430/1
25/02/2019	5/03/2019	13/03/2019	0	Batch 19/0487/1
5/03/2019	12/03/2019	13/03/2019	0	Batch 19/0562/1
12/03/2019	19/03/2019	26/03/2019	0	Batch 19/0623/1
19/03/2019	25/03/2019	26/03/2019	0	Batch 19/0681/1
26/03/2019	1/04/2019	11/04/2019	0	Batch 19/0747/1
2/04/2019	9/04/2019	11/04/2019	0	Batch 19/0822/1
9/04/2019	16/04/2019	29/04/2019	0	Batch 19/0880/1
16/04/2019	23/04/2019	29/04/2019	0	Batch 19/0936/1
23/04/2019	30/04/2019	8/05/2019	0	Batch 19/0964/1
30/04/2019	7/05/2019	8/05/2019	0	Batch 19/1033/1
7/05/2019	16/05/2019	21/05/2019	0	Batch 19/1090/1
14/05/2019	20/05/2019	21/05/2019	0	Batch 19/1156/1
21/05/2019	23/05/2019	4/06/2019	0	Batch 19/1209/1
28/05/2019	3/06/2019	4/06/2019	0	Batch 19/1258/1
4/06/2019	14/06/2019	14/06/2019	0	Batch 19/1315/1
11/06/2019	13/06/2019	14/06/2019	0	Batch 19/1358/1
18/06/2019	20/06/2019	27/06/2019	0	Batch 19/1419/1
25/06/2019	2/07/2019	3/07/2019	0	Batch 19/1471/1

Sample Point 15 - Effluent Quality Monitoring - Coffs Harbour Reuse
 Reporting Period: 1 July 2018 to 30 June 2019
 Test Frequency: Monthly with additional weekly tests required by Council

[Click here to access this licence on the EPA website](#)

Notes:

Cells highlighted indicate results that reach Council's 90 and 100 percentile limits

Date Sample Collected	Date Obtained	Date Published	Faecal Colliforms cfu/100ml	Comments
3/07/2018	10/07/2018	16/07/2018	0	Batch 18/1422/1
10/07/2018	17/07/2018	18/07/2018	0	Batch 18/1479/1
16/07/2018	18/07/2018	18/07/2018	0	Batch 18/1526/1
24/07/2018	26/07/2018	6/08/2018	0	Batch 18/1579/1
31/07/2018	6/08/2018	6/08/2018	0	Batch 18/1623/1
7/08/2018	16/08/2018	24/08/2018	0	Batch 18/1670/1
14/08/2018	20/08/2018	24/08/2018	0	Batch 18/1727/1
28/08/2018	3/09/2018	6/09/2018	0	Batch 18/1830/1
4/09/2018	11/09/2018	24/09/2018	0	Batch 18/1897/1
11/09/2018	14/09/2018	24/09/2018	1	Batch 18/1956/1
12/09/2018	13/09/2018	24/09/2018	0	Batch 18/1977/1 - Repeat test
18/09/2018	24/09/2018	4/10/2018	0	Batch 18/2016/1
25/09/2018	2/10/2018	4/10/2018	0	Batch 18/2067/1
2/10/2018	9/10/2018	18/10/2018	0	Batch 18/2122/1
9/10/2018	12/10/2018	18/10/2018	0	Batch 18/2194/1
16/10/2018	19/10/2018	31/10/2018	0	Batch 18/2244/1
23/10/2018	26/10/2018	31/10/2018	0	Batch 18/2303/1
30/10/2018	6/11/2018	9/11/2018	0	Batch 18/2368/1
6/11/2018	14/11/2018	22/11/2018	0	Batch 18/2424/1
13/11/2018	20/11/2018	22/11/2018	0	Batch 18/2504/1
20/11/2018	27/11/2018	11/12/2018	0	Batch 18/2569/1
27/11/2018	4/12/2018	17/12/2018	0	Batch 18/2640/1
4/12/2018	11/12/2018	17/12/2018	0	Batch 18/2698/1
11/12/2018	18/12/2018	18/12/2018	0	Batch 18/2764/1
18/12/2018	2/01/2019	14/01/2019	3	Batch 18/2822/1
20/12/2019	2/01/2019	14/01/2019	0	Batch 18/2863/1
2/01/2019	9/01/2019	14/01/2019	0	Batch 19/0003/1
8/01/2019	14/01/2019	14/01/2019	0	Batch 19/0065/1
15/01/2019	21/01/2019	25/01/2019	11	Batch 19/0142/1
22/01/2019	29/01/2019	7/02/2019	0	Batch 19/0195/1
29/01/2019	31/01/2019	7/02/2019	2	Batch 19/0250/1
31/01/2019	1/02/2019	7/02/2019	0	Batch 19/0279/1 - Repeat Test
5/02/2019	14/02/2019	26/02/2019	0	Batch 19/0310/1
12/02/2019	19/02/2019	26/02/2019	0	Batch 19/0365/1
19/02/2019	25/02/2019	26/02/2019	0	Batch 19/0421/1
26/02/2019	5/03/2019	13/03/2019	0	Batch 19/0482/1
5/03/2019	12/03/2019	13/03/2019	0	Batch 19/0551/1
12/03/2019	19/03/2019	26/03/2019	0	Batch 19/0615/1
19/03/2019	25/03/2019	26/03/2019	0	Batch 19/0692/1
26/03/2019	1/04/2019	11/04/2019	0	Batch 19/0740/1
2/04/2019	9/04/2019	11/02/2019	0	Batch 19/0810/1
9/04/2019	16/04/2019	29/04/2019	0	Batch 19/0880/1
16/04/2019	23/04/2019	29/04/2019	0	Batch 19/0936/1
23/04/2019	30/04/2019	8/05/2019	0	Batch 19/0958/1
30/04/2019	7/05/2019	8/05/2019	0	Batch 19/1019/1
7/05/2019	16/05/2019	21/05/2019	0	Batch 19/1083/1
14/05/2019	20/05/2019	21/05/2019	0	Batch 19/1147/1
21/05/2019	23/05/2019	4/06/2019	0	Batch 19/1201/1
28/05/2019	3/06/2019	4/06/2019	0	Batch 19/1246/1
4/06/2019	14/06/2019	14/06/2019	0	Batch 19/1308/1
11/06/2019	13/06/2019	14/06/2019	0	Batch 19/1346/1
18/06/2019	20/06/2019	27/06/2019	0	Batch 19/1407/1
25/06/2019	2/07/2019	3/07/2019	0	Batch 19/1488/1

SAMPLE POINT DATA
EPA Licence 573
Coffs Harbour City Council
Locked Bag 155
Coffs Harbour NSW 2450



Sample Point 19 - Effluent Quality Monitoring - Corindi Reuse Onsite
 Reporting Period: 1 July 2018 to 30 June 2019
 Test Frequency: Monthly with additional tests required by Council

[Click here to access this licence on the EPA website](#)

Notes:

Cells highlighted indicate results that reach Council's 90 and 100 percentile limits

Date Sample Collected	Date Obtained	Date Published	Faecal Coliforms cfu/100ml	Comments
16/07/2018	17/07/2018	18/07/2018	0	Batch 18/1517/1
24/07/2018	26/07/2018	6/08/2018	0	Batch 18/1574/1
31/07/2018	6/08/2018	6/08/2018	0	Batch 18/1618/1
7/08/2018	16/08/2018	24/08/2018	2	Batch 18/1665/1
8/08/2018	9/08/2018	24/08/2018	0	Batch 18/1692/1 - Repeat test
14/08/2018	20/08/2018	24/08/2018	0	Batch 18/1730/1
23/10/2018	26/10/2018	31/10/2018	0	Batch 18/2313/1
30/10/2018	6/11/2018	9/11/2018	0	Batch 18/2362/1
7/11/2018	14/11/2018	22/11/2018	0	Batch 18/2444/1
13/11/2018	21/11/2018	22/11/2018	0	Batch 18/2517/1
20/11/2018	27/11/2018	11/12/2018	0	Batch 18/2575/1
27/11/2018	4/12/2018	17/12/2018	0	Batch 18/2636/1
4/12/2018	11/12/2018	17/12/2018	0	Batch 18/2704/1
10/12/2018	18/12/2018	18/12/2018	0	Batch 18/2734/1
3/01/2019	9/01/2019	14/01/2019	0	Batch 19/0042/1
8/01/2019	15/01/2019	25/01/2019	0	Batch 19/0060/1
23/01/2019	29/01/2019	7/02/2019	0	Batch 19/0217/1
29/01/2019	4/02/2019	7/02/2019	0	Batch 19/0246/1

SAMPLE POINT DATA
EPA Licence 573



Sample Point 22 - Effluent Quality Monitoring - Corindi Reuse Offsite
 Reporting Period: 1 July 2018 to 30 June 2019
 Test Frequency: Monthly with additional weekly tests required by Council

[Click here to access this licence on the EPA website](#)

Notes:

Cells highlighted indicate results that reach Council's 90 and 100 percentile limits

Date Sample Collected	Date Obtained	Date Published	Faecal Coliforms cfu/100ml	Comments
3/07/2018	10/07/2018	16/07/2018	0	Batch 18/1419/1
10/07/2018	16/07/2018	18/07/2018	0	Batch 18/1495/1
16/07/2018	18/07/2018	18/07/2018	0	Batch 18/1516/1
24/07/2018	26/07/2018	6/08/2018	0	Batch 18/1575/1
31/07/2018	6/08/2018	6/08/2018	0	Batch 18/1619/1
7/08/2018	16/08/2018	24/08/2018	2	Batch 18/1666/1
8/08/2018	9/08/2018	24/08/2018	2	Batch 18/1692/2
14/08/2018	20/08/2018	24/08/2018	0	Batch 18/1731/1
21/08/2018	23/08/2018	6/09/2018	0	Batch 18/1783/1
28/08/2018	3/09/2018	6/09/2018	0	Batch 18/1836/1
4/09/2018	5/09/2018	6/09/2018	1	Batch 18/1889/1
5/09/2018	6/09/2018	6/09/2018	0	Batch 18/1919/1
11/09/2018	14/09/2018	24/09/2018	0	Batch 18/1963/1
18/09/2018	24/09/2018	4/10/2018	0	Batch 18/2026/1
25/09/2018	2/10/2018	4/10/2018	0	Batch 18/2072/1
2/10/2018	9/10/2018	18/10/2018	0	Batch 18/2157/1
9/10/2018	12/10/2018	18/10/2018	0	Batch 18/2193/1
16/10/2018	19/10/2018	31/10/2018	0	Batch 18/2263/1
23/10/2018	26/10/2018	31/10/2018	0	Batch 18/2312/1
30/10/2018	31/10/2018	9/11/2018	134	Batch 18/2363/1 - Final
31/10/2018	1/11/2018	9/11/2018	0	Batch 18/2390/1
7/11/2018	14/11/2018	22/11/2018	0	Batch 18/2445/1
13/11/2018	21/11/2018	22/11/2018	0	Batch 18/2518/1
20/11/2018	27/11/2018	11/12/2018	0	Batch 18/2576/1
27/11/2018	4/12/2018	17/12/2018	0	Batch 18/2637/1
4/12/2018	11/12/2018	17/12/2018	0	Batch 18/2705/1
10/12/2018	18/12/2018	18/12/2018	0	Batch 18/2735/1
18/12/2018	2/01/2019	14/01/2019	TNTC	Batch 18/2833/1 - Resampled following day.
19/12/2018	20/12/2019	14/01/2019	0	Batch 18/2844/1 - Repeat test clear.
20/12/2018	2/01/2019	14/01/2019	0	Batch 18/2870/1
3/01/2019	9/01/2019	14/01/2019	0	Batch 19/0041/1
8/01/2019	15/01/2019	25/01/2019	0	Batch 19/0061/1
15/01/2019	21/01/2019	25/01/2019	0	Batch 19/0139/1
23/01/2019	24/01/2019	7/02/2019	2	Batch 19/0216/1
29/01/2019	4/02/2019	7/02/2019	0	Batch 19/0247/1
31/01/2019	4/02/2019	7/02/2019	0	Batch 19/0280/1
5/02/2019	14/02/2019	26/02/2019	0	Batch 19/0320/1
12/02/2019	19/02/2019	26/02/2019	0	Batch 19/0371/1
19/02/2019	25/02/2019	26/02/2019	0	Batch 19/0431/1
25/02/2019	5/03/2019	13/02/2019	0	Batch 19/0488/1
5/03/2019	12/03/2019	13/03/2019	0	Batch 19/0563/1
12/03/2019	13/03/2019	26/03/2019	6	Batch 19/0624/1 - Resampled following day.
14/03/2019	18/03/2019	26/03/2019	0	Batch 19/0648/1 - Repeat test clear.
19/03/2019	25/03/2019	26/03/2019	0	Batch 19/0682/1
26/03/2019	1/04/2019	11/04/2019	0	Batch 19/0748/1
2/04/2019	9/04/2019	11/04/2019	0	Batch 19/0825/1
9/04/2019	16/04/2019	29/04/2019	0	Batch 19/0881/1
16/04/2019	23/04/2019	29/04/2019	0	Batch 19/0937/1
23/04/2019	30/04/2019	8/05/2019	0	Batch 19/0965/1
30/04/2019	1/05/2019	8/05/2019	2	Batch 19/1034/1 - Resampled following day.
2/05/2019	6/05/2019	8/05/2019	0	Batch 19/1059/1 - Repeat test clear.
7/05/2019	9/05/2019	21/05/2019	30	Batch 19/1091/1 - Chlorine pump failed, resample when repaired
15/05/2019	16/05/2019	21/05/2019	0	Batch 19/1174/1 - Repeat test clear. Pump repaired
21/05/2019	23/05/2019	4/06/2019	0	Batch 19/1210/1
28/05/2019	29/05/2019	4/06/2019	2	Batch 19/1259/1 - Resample following day
29/05/2019	30/05/2019	4/06/2019	0	Batch 19/1280/1 - Resample test clear
4/06/2019	14/06/2019	14/06/2019	0	Batch 19/1316/1