Coffs Harbour Drinking Water Quality Report - February 2022

Results for the 12 months from February 2021 to January 2022 from the NSW Health Drinking Water Monitoring Program

Water Quality Parameter		Unit of Measurement	Avg	Min	Max	ADWG^ Health Guideline Value	% Compliance	ADWG^ Aesthetic Guideline Value	% Compliance	No. of Samples
Physical	Alkalinity (as $CaCO_3$)*	mg/L	43.38	32.15	56.74	-	-	-	-	51
	pH	-	7.71	7.50	7.90	-	-	6.5 - 8.5	100	11
	Total Dissolved Solids (TDS)	mg/L	88.91	81.00	100.00	-	-	600 mg/L	100	11
	Total Hardness (as $CaCO_3$)	mg/L	61.97	54.50	72.00	-	-	200 mg/L	100	11
	True Colour	HU	0.59	0.50	1.00	-	-	15 HU	100	11
	Turbidity	NTU	0.22	0.05	0.60	-	-	5 NTU	100	11
Chemical	Aluminium	mg/L	0.02	0.01	0.03	-	-	0.2mg/L	100	11
	Copper	mg/L	0.05	0.01	0.13	2mg/L	100	1mg/L	100	11
	Fluoride	mg/L	0.97	0.87	1.04	1.5mg/L	100	-	-	11
	Iron	mg/L	0.02	0.01	0.11	-	-	0.3mg/L	100	11
	Lead	mg/L	0.00	0.00	0.00	0.01mg/L	100	-	-	11
	Manganese	mg/L	0.00	0.00	0.00	0.5mg/L	100	0.1mg/L	100	11
Microbial	*E.coli*	cfu/100ml	0.00	0.00	0.00	0 in 100ml	100	-	-	591

^ Australian Drinking Water Guidelines 2011

\- No Guideline Value exists

* Test by Environmental Laboratory

Published by Coffs Harbour Water on *24/02/2022*

COFFS HARBOUR WATER