Karangi WTP OEMP Complaints Register

Date	Complaint	Action 1	Action 2
21/01/2010	Complaint that pumps at Water Treatment	Arranged for pumps to be off from midnight to 6 am each day	Sound study undertaken by GHD found that full
	Filtration Plant opposite are a noise problem from	unless unforseen circustances occur. This is a temporary	operation meets regulations. Called complainant
	4:00am in the mornings.	measure, while soundproofing of the Treated Water Pump Station	28/4/10 and advised them of this fact and that
		is investigated. Contacted complainant and they seemed	Council would resume normal operations ASAP.
		happy that the issue is being addressed.	Advised them to call if further issues develop. The
			noise study stated that the noise the complainant
			heard may have come from the Transgid site. I
			asked them about the noise, and they stated that
			they did not really know here the noise was coming
			from.